SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 2025/967/973

Date 14.06.2025

It is certified that Ms. Vandana Deswal, Chemist, Public Health Engineering Department, District Water Testing Laboratory, Faridabad, tested the water samples of Rawal Public School, Sector-64, Milk Plant Mohna Road, Ballabgarh, Faridabad-121004 on 05.06.2025 and on the basis of Water Test Report – Physical/Chemical and Bacteriological (Attached) bearing no TC-9082 Dated 12.06.2025 and no. 973 dated 12.06.2025, respectively, it is certified that Rawal Public School, Sector-64, Milk Plant Mohna Road Ballabgarh, Faridabad-121004 has safe drinking water facilities for the students and members of staff of the institution.

I have inspected the school and found that the school also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central / State / U.T. Govt.

This certificate is valid for a duration of one year from the date of issue.

Signature with seal 14/6/2025

Name DR. KHARI

Designation M.O, E.S.I., Fbd

Medical Officer
E. S. I. HOSPITAL
Sector-8, Faridaba

PUBLICHEALTHENGINEERINGDEPARTMENT

DISTRICTWATERTESTINGLABORATORY,FARIDABAD

Website :- https://phedharyana.gov.in/

Memo No:-967 Date:-12/06/2025

Certificate No:TC-9082

Subject : Physical / Chemical Examination Report of Water Sample

Sample ID/Classification:	FBD/01246/6/2025/Private Sender	**Sample Details**	**Date &Time**
:	Rawal Public School	Collected By	Jagat Singh
Location :	, Sectpr 64, Ballabgarh	Collection Date	03/06/2025 at 14:09
		Received at lab	04/06/2025 at 10:48
Sample Description :	Drinking Water	Analysis Start Date	05/06/2025
Latitute / Longitude :	77.337307 / 28.330059	Analysis End Date	06/06/2025
		Sample Quantity	1 Litre

Test Result(As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)	Protocol Used
1	Turbidity	0.67	1NTU	5NTU	APHA 24th edition,2130B:2023
2	Taste	Agreeable	Agreeable	Agreeable	IS 3025(Part8):2023
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025(Part5):2018
4	Color	6	5 Hazen Units	15 Hazen Units	APHA 24th EDITION-2120C:2023
5	Total Dissolved Solids @ 180°c ± 2°c	96	500mg/lt.	2000mg/lt.	APHA 24th Edition-2540 C
6	Total Hardness as CaCo3	70	200mg/lt.	600mg/lt.	APHA 24th Edition-2340C
7	Calcium as Ca	16.03	75 mg/lt.	200mg/lt.	APHA 24th Edition-3500-Ca B
8	Magnesium as Mg	7.29	30 mg/lt.	100mg/lt.	APHA 24th Edition-3500 Mg B
9	Total Alkalinity	70	200mg/lt.	600mg/lt.	APHA 24th Edition-2320B
10	Chloride as Cl	55.36	250mg/lt.	1000mg/lt.	APHA 24th Edition-4500Cl-B
11	Sulphate as So4	31	200mg/lt.	400mg/lt.	USEPA /APHA 24th-4500SO4-E
12	Fluoride as F	0.12	1.0mg/lt.	1.5mg/lt.	APHA 24th Edition4500F-D:
13	Iron as Fe	0.03	1.0mg/lt.	1.0mg/lt.	USEPA 45(126:43459):2023,APHA 24th EDITION 3500-Fe-B
14	Nitrate as No3	2.5	45 mg/lt.	45 mg/lt.	APHA 24th Edition-4500 NO3 D
15	pH @ 25°c	7.12	6.5-8.5	6.5-8.5	APHA 24th Edition4500-H+B

Remarks :-

* The Results Given above are related to the sample as received and tested in PHED FARIDABAD Lab.
* The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
* The test report can't be used for any publicity or any legal purpose.
* Reliability of water sample sample lies with sender/collector of water sample.
* To check the sample report online Scan the QR Code below.
* Thetestsamplesmeantforchemicalanalysiswillbedisposedoffafter7daysfromthedataofissueoftest report unless untill specifically requested by the customer for retaining over a longer period.

Sample analyzed by :

VANDANA DESWAL ,CHEMIST
DISTRICTWATER TESTING LABORATORY,FARIDABAD
email:-chemist.fbad@phedharyana.gov.in

PUBLIC HEALTH ENGINEERING DEPARTMENT

DISTRICT WATER TESTING LABORATORY ,FARIDABAD

PHED Haryana

Website :- https://phedharyana.gov.in/

Memo No:- 973 Date:- 12-06-25

Subject : Bacteriological Examination Report of Water Sample

Sample ID:	FBD/01245/6/2025		
Sample Classification:	Private		
Sender:	Rawal Public School		
Location :-	, Sector-64, Ballabgarh		
Latitute :-	77.337307	Longitude :-	28.330062

Sample Details	Date & Time
Collected By	Jagat Singh,9891017678
Collection Date	03/06/2025 at 13:59
Received at lab	04/06/2025 at 10:48
Tested at Lab	12/06/2025

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Protocol Used
1	Total Coliform per 100 ml	0	Shall not be detectable in any 100 ml sample	IS 15185:2016/APHA 9223B-2023/APHA 9221C-2023
2	E-Coli (MPN/100 ml.)	0	Shall not be detectable in any 100 ml sample	IS 15185:2016/APHA 9223B-2023/APHA 9221F-2023

Remarks :-

* The Results Given above are related to the sample as received and tested in FARIDABAD lab.
* The tesi report can't be regenerated in whole or part there of without written permission of Competent Authority.
* The test report can't be used for any publicity or any legal purpose.
* Reliability of water sample sample lies with sender/collector of water sample.
* To check the sample report online Scan the QR Code below.

Water Sample has been found "**CONFORMING** " to Limits set in BIS10500:2012 for the tested parameters.
Based on the tested parameters,the water sample is found **"POTABLE"**

Vandana

VANDANA DESWAL,CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING
LABORATORY,FARIDABAD
email:-chemist.fbad@phedharyana.gov.in

------End of Report------.

----------WATER IS LIFE,SAVE IT----------